



ACTUATOR SPECIFICATION

| | |
|-----------------|--------------------------------|
| Enclosure | IP54 (DIN40050, IEC144) |
| Power supply | 24V AC $\pm 10\%$ |
| Rated current | 0.069 A |
| Nominal force | 2000N |
| Nominal stroke | 20mm |
| Operating time | 55 sec |
| Manual override | Hand/Auto Decutching mechanism |
| Condenser | 33 ? |
| Conduit | PF 1/2" TAP |

| DIMENSIONS | | | | | UNIT : mm |
|------------|-----|----|-----|-----|-----------|
| N D | A | H1 | H2 | H3 | |
| 15A | 100 | 54 | 326 | 380 | |
| 20A | 100 | 68 | 326 | 394 | |
| 25A | 105 | 69 | 334 | 403 | |
| 32A | 105 | 66 | 334 | 400 | |
| 40A | 130 | 85 | 346 | 431 | |
| 50A | 130 | 89 | 346 | 435 | |

NOMINAL PRESSURE : 10 kg/cm²

| | | | | |
|--------|---------------|----------|------|--------|
| 6 | ACTUATOR | JEA-20 | 1 | |
| 5 | STEM | STS304 | 1 | |
| 4 | PACKING | VITON | 1 | |
| 3 | DISC | STS304 | 1 | |
| 2 | COVER | BC6 | 1 | |
| 1 | BODY | BC6 | 1 | |
| P.N.D. | PART NAME | MATERIAL | Q'TY | REMARK |
| | FIRST ISSUE | 02.05.22 | | |
| REV NO | REVISION NOTE | DATE | DRW | APP |

3-WAY CONTROL VALVE

| | |
|-------------|-------------|
| FILE NAME | JSV-3S-1550 |
| DWG | DWG |
| DWG | DWG |
| DWG | DWG |
| SCALE : N/S | |
| DWG NO | JSV-005 |



제이에스밸브